

LED Double Ended Type B U1 Tubes (120V to 277V)



The Type B LED U1 Tubes listed above are to be used with 2G13 (medium bi-pin) lamp holders that are either internally or externally shunted.



BEFORE YOU BEGIN

Read these instructions completely and carefully.

LED13BDT8/U/XYY#

X is a number representing CRI; YY are numbers representing CCT, # may be any character(s) representing additional lamp features


To install the Type B LED U1, please read the entire installation guide carefully. To protect against future misapplication, Current recommends installing an in-line fuse: Type 2AG, rated at 1 amp, 350 volts, Littlefuse part number 0209001 MXP or equivalent. Available through Current, BT8-1AFUSEKIT.

Ensure that package includes installation guide, warning label to be attached to luminaire, LED U1 tube. Minimum fixture volume for 3 lamps is 24 inches long x 24 inches wide x 3.2 inches deep. Minimum socket spacing is 3.15 inches apart. Product is not intended to be used with dimmers or emergency lighting. This LED U1 tube is not suitable for direct replacement of linear fluorescent lamps in luminaires where the lamps are connected to a ballast. The technical and safety requirements of the converted luminaire are the sole responsibility of the party doing the conversion and shall comply with the local applicable safety and regulatory laws and standards. The provided Caution label should be placed onto the converted luminaire to indicate that the luminaire has been modified and can no longer be used with conventional fluorescent lamps.

! WARNING

RISK OF FIRE OR ELECTRIC SHOCK: LED Retrofit Kit installation requires knowledge of luminaire electrical systems. If not qualified, do not attempt installation. Contact a qualified electrician. Install this kit only in luminaires that have the construction features and dimensions shown in the drawings and where the input rating of the retrofit kit does not exceed the input rating of the luminaire. To prevent wiring damage or abrasion, do not expose wiring to edges of sheet metal or other sharp objects. Installers should not disconnect existing wires from lampholder terminals to make new connections at lampholder terminals. Instead installers should cut existing lampholder leads away from the lampholder and make new electrical connections to the lampholder lead wires by employing applicable connectors (or replace with new shunted lamp holders). THE RETROFIT KIT IS ACCEPTED AS A COMPONENT OF A LUMINAIRE WHERE THE SUITABILITY OF THE COMBINATION SHALL BE DETERMINED BY AUTHORITIES HAVING JURISDICTION. PRODUCT MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN IN ACCORDANCE WITH THE APPLICABLE AND APPROPRIATE ELECTRICAL CODES. THE INSTALLATION GUIDE DOES NOT SUPERSEDE LOCAL OR NATIONAL REGULATIONS FOR ELECTRICAL INSTALLATIONS. Do not make or alter any open holes in an enclosure of wiring or electrical components during kit installation. Installers should examine all parts that are not intended to be replaced by the retrofit kit for damage and replace any damaged parts prior to installation of the retrofit kit. This lamp operates directly from 120V-277V mains. Do not use Ballast or any starting aid. Do not connect to a voltage higher than 277 volts. To reduce risk of misapplication, Current recommends installing the Fuse Kit (BT8-1AFUSEKIT) in series with the Phase or Hot lead and the SHUNTED (Instant Start style) lamp holder(s) per the wiring diagrams below. Only one fuse kit is needed for up to 4 tubes in the same fixture at 277V. Ensure the lamp holders are SHUNTED for Double Ended U1 applications.

Installation Instructions



- 1 Ensure power is off to luminaire by disconnecting the supply voltage.
- 2 Remove all fluorescent lamps and ballast/wiring area cover. Cut the ballast lead wires about 6 inches away from each lamp holder.

- 3 - 7 3) If two wires come from an existing lamp holder (rapid start type), these two wires should be wired or shunted together.
- 4) Connect the recommended fuse and fuseholder (not supplied) to the black (hot) wire from the mains.
- 5) Connect together all of the lampholder leads on one side and connect to the other side of the recommended fuse with suitable wire.
- 6) Connect together all of the lamp holder leads on the other side of the fixture and connect to the white or neutral wire from the mains.
- 7) Replace the ballast / wiring area cover, ensuring no wires are pinched between the cover and the fixture.

- 8) Install the retrofit kit Caution label in an easy to see location to ensure the user understands the system now uses LED Type B double ended tubes, and the use of fluorescent lamps may result in damage or injury.
- 9) Install Type B double ended tubes.
- 10) Re-apply power to fixture and ensure proper operation.

This lamp is designed for general lighting service. This lamp may not be suitable for use in all applications where a conventional fluorescent lamp has been used.

This Class A device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation. Any changes or modifications not expressly approved by the manufacturer could void the user's authority to operate the equipment. This device complies with CAN ICES-005A.

NOTE: This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

Type B LAMP – intended for operation in luminaires with traditional fluorescent-type lampholders wired directly to the branch circuit. This includes both factory-wired luminaires as well as those converted for this purpose under a retrofit program.

Tubes U1 à DEL de type B à double culot (120 V à 277 V)



Les tubes U1 à DEL de type B listés ci-dessus doivent être utilisés avec des douilles de lampe 2G13 (bi-broches moyennes) qui sont shuntées en interne ou en externe.



AVANT DE COMMENCER

Lire attentivement et entièrement ces instructions

LED13BDT8/U/YYY#

X est un nombre représentant CRI; YY sont des nombres représentant CCT, # peut être n'importe quel caractère représentant des caractéristiques supplémentaires de la lampe


Pour installer les tubes U1 à DEL de type B, veuillez lire attentivement le guide d'installation dans son intégralité. Pour protéger les tubes contre une mauvaise utilisation future, Current recommande d'installer un fusible en ligne : type 2AG, avec une tension nominale de 1 ampère, 350 volts, Littelfuse référence 0209001 MXP ou équivalent. Disponible via Current, BT8-1AFUSEKIT.

Assurez-vous que l'emballage comprend un guide d'installation, une étiquette d'avertissement à fixer au luminaire et un tube U1 à DEL. Le volume minimum de luminaire pour 3 lampes est d'environ 61 cm de long x 61 cm de large x 8 cm de profondeur. L'espace minimum entre les douilles est de 8 cm. Le produit n'est pas conçu pour être utilisé avec des gradateurs ou des luminaires d'urgence. Ce tube U1 à DEL ne convient pas pour le remplacement direct d'une lampe fluorescente linéaire dans les luminaires où les lampes sont connectées à un ballast. Les exigences techniques et de sécurité du luminaire converti sont la seule responsabilité de la partie qui procède à la conversion et doivent être conformes aux lois et aux normes locales applicables en matière de sécurité et de réglementation. L'étiquette Attention fournie doit être placée sur le luminaire converti pour indiquer que ce dernier a été modifié et ne peut plus être utilisé avec des lampes fluorescentes conventionnelles.

AVERTISSEMENT

RISQUE D'INCENDIE OU DE DÉCHARGE ÉLECTRIQUE: L'installation du kit de conversion DEL nécessite une connaissance des systèmes électriques des luminaires. Si vous n'êtes pas qualifié, n'essayez pas d'effectuer l'installation. Contactez un électricien qualifié. Installez ce kit uniquement dans des luminaires qui ont les caractéristiques de construction ainsi que les dimensions indiquées dans les dessins ci-joints et dont la tension nominale est égale ou excède la tension nominale du kit de conversion. Pour éviter l'endommagement ou l'abrasion du câblage, ne pas exposer ce dernier aux bords d'une tôle ou de tout autre objet pointu. Les installateurs ne doivent pas débrancher les fils existants des bornes de la douille afin de réaliser de nouvelles connexions au niveau de ces bornes. Les installateurs doivent plutôt couper les fils existants de la douille pour les écarter de celle-ci, puis réaliser de nouvelles connexions aux fils de la douille, au moyen de connecteurs appropriés (ou remplacer par des nouvelles douilles shuntées). LE NÉCESSAIRE DE MODERNISATION EST ACCEPTÉ À TITRE DE COMPOSANT D'UN LUMINAIRE LORSQUE LA PERTINENCE DE LA COMBINAISON DOIT ÊTRE DÉTERMINÉE PAR LES AUTORITÉS COMPÉTENTES. CE PRODUIT DOIT ÊTRE MIS EN PLACE PAR UN ÉLECTRICIEN QUALIFIÉ CONFORMÉMENT AUX CODES ÉLECTRIQUES APPROPRIÉS APPLICABLES. LE GUIDE D'INSTALLATION NE SUPPLANTE PAS LES RÈGLEMENTS LOCAUX OU NATIONAUX EN MATIÈRE D'INSTALLATIONS ÉLECTRIQUES. Ne pas ajouter de trous ni modifier les trous existants de tout boîtier de câblage ou de composants électriques lors de l'installation du kit. Les installateurs doivent examiner toutes les pièces qui ne seront pas remplacées par le kit de conversion pour déceler des dommages et remplacer toute pièce endommagée avant l'installation du kit de conversion. Cette lampe fonctionne directement sur le secteur 120V-277V. N'utilisez pas de ballast ni d'aide au démarrage. Ne pas connecter à une tension supérieure à 277 volts. Pour réduire le risque de mauvaise utilisation, Current recommande d'installer le kit de fusibles (BT8-1 AFUSEKIT) en série avec le fil de phase ou le fil sous tension et les douilles (à allumage instantané) SHUNTÉES selon les schémas de câblage ci-dessous. Un seul kit de fusibles est nécessaire pour une utilisation allant jusqu'à 4 tubes dans le même luminaire à 277V. Assurez-vous que les douilles sont SHUNTÉES pour les applications U1 double extrémité.

Instructions d'installation



Cette lampe est conçue pour fournir un éclairage général. Cette lampe peut ne pas convenir à toutes les applications où une lampe fluorescente traditionnelle a été utilisée.

Cet appareil est conforme à la partie 15 des règlements de la FCC. Le fonctionnement de cet appareil est assujetti aux deux conditions suivantes: (1) cet appareil ne devrait pas causer d'interférences préjudiciables ; et (2) cet appareil doit accepter toute interférence reçue, y compris celle pouvant causer un fonctionnement indésirable. Tout changement ou modification non expressément approuvé par le fabricant peut annuler le droit de l'utilisateur à utiliser l'équipement. Cet appareil est conforme à la norme canadienne NMB-005A.

Remarque: Cet appareil a été testé et reconnu conforme aux limites établies pour les appareils numériques de classe A, selon la section 15 des règlements de la FCC. Ces limites visent à fournir une protection raisonnable contre l'interférence préjudiciable lorsque l'équipement est utilisé en milieu commercial. Cet équipement produit et utilise une énergie de fréquence radio qui peut irradier de celui-ci, et si l'équipement n'est pas installé et utilisé conformément au mode d'emploi, il peut causer une interférence préjudiciable aux communications radio. L'utilisation de cet équipement en milieu résidentiel est susceptible de causer une interférence préjudiciale, auquel cas l'utilisateur devra corriger l'interférence à ses frais.

LAMPE DE TYPE B – Destiné à fonctionner dans des luminaires avec douilles de type fluorescent traditionnelles câblées directement sur le circuit de dérivation. Cela comprend à la fois les luminaires câblés en usine ainsi que ceux convertis à cet effet dans le cadre d'un programme de rénovation.