




## INSTALLATION INSTRUCTIONS - SE SERIES EXIT LIGHT FIELD KIT

### EMERGENCY OPERATION MODULE

REMOVE EXISTING PC BOARD.  
SLIDE EM PC BOARD INTO RETAINER  
SLOTS.

PLUG 2-PIN BATTERY LEAD  
CONNECTOR ONTO PC BOARD.

INSERT BATTERY PACK INTO  
COMPARTMENT USING DOUBLE-  
SIDED TAPE TO SECURE.



PLUG TRANSFORMER  
SECONDARY CONNECTOR  
ONTO PC BOARD.

93031341

**NOTE:** BATTERIES MAY BE  
SHIPPED UNCHARGED.  
CHARGE BATTERIES FULLY  
BEFORE TESTING.

**NOTE:** REMOVE ANY EXISTING LABELS AS  
REQUIRED. CLEAN BOTTOM OF SIGN AND  
APPLY AC ON/PUSH TO TEST LABEL OVER  
INDICATOR OPENING AS SHOWN.

## IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following.

### READ AND FOLLOW ALL SAFETY INSTRUCTIONS

1. Do not use outdoors.
2. Do not let power supply cords touch hot surfaces.
3. Do not mount near gas or electric heaters.
4. Equipment should be mounted in locations and at heights where it will not readily be subjected to tampering by unauthorized personnel.
5. The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
6. Do not use this equipment for other than intended use.
7. Servicing of this equipment should be performed by qualified service personnel.

### SAVE THESE INSTRUCTIONS

For additional installation, operation and maintenance information refer to instruction sheet 93028841 supplied with exit sign.

### Warning:

This product contains chemicals known to the state of California to cause cancer, birth defects, and/or other reproductive harm. Thoroughly wash hands after installing, handling, cleaning, or otherwise touching this product.

93031341