



NOTES:

1. Power down prior to installation.
2. Not to exceed more than 6 Sensors per UVPPHD. Auxiliary Packs count as a sensor slot.
3. If a Line voltage switch is used the sensor(s) will not be able to turn on the fixture if the switch is in the OFF position.



HUBBELL
Control Solutions

(864) 678-1000
(866) 898-0131 fax

701 Millennium Blvd.
Greenville, SC 29607

UVPPHD with LOIRWVRP-LWO Sensors

THIS DOCUMENT AND SPECIFICATIONS DESCRIBED WITHIN ARE THE EXCLUSIVE PROPERTY OF HUBBELL CONTROL SOLUTIONS ISSUED IN THE STRICTEST CONFIDENCE, AND SHALL NOT BE REPRODUCED, COPIED OR USED WITHOUT PRIOR WRITTEN PERMISSION.