


NOTE:

Disconnect power prior to installation.

For SpectraSync applications, the highest CCT LED should be on CH1 and the lower CCT LED should be on CH2.

TITLE: NXSMP-LMI USING THE NXFM-O AND CTC DRIVER	
 HUBBELL Control Solutions	THIS DOCUMENT AND SPECIFICATIONS DESCRIBED WITHIN ARE THE EXCLUSIVE PROPERTY OF HUBBELL CONTROL SOLUTIONS ISSUED IN THE STRICTEST CONFIDENCE, AND SHALL NOT BE REPRODUCED, COPIED OR USED WITHOUT PRIOR WRITTEN PERMISSION.
	DRAWN BY: AJ DATE: 09/13/2017 PRODUCT FAMILY: NX
701 Millennium Blvd. Greenville, SC 29607 www.Hubbell-Automation.com	Main Switchboard: (864) 678-1000 Technical Service: (800) 888-8006