



Notes:

1. If only controlling 1 load, use Black, Red, and Green wires
2. Black and Red wires operate through Button 1
3. Blue and Violet wires operate through Button 2
4. For each circuit a RIB relay will be required.
5. The auxiliary contacts (N.O. or N.C.) to be used to interact with an input device is dependant on that system.



**LHMTD2 Dual Circuit - with
RR1SPDTC to Low Voltage inputs**



Building Automation, Inc.